

Commandant United States Coast Guard U.S. Coast Guard (CG-ENG-4) 2703 Martin Luther King Jr. Ave., S.E. Stop 7509 Washington, DC 20593-7509 Phone: (202) 372-1392 Fax: (202) 372-8379 Email: TypeApproval@uscg.mil http://www.uscg.mil/hq/cq5/cq5214/

16714/164.139/7 Corr. 2014-733 September 19, 2014

Alex Talwar Greenheck Fan Corporation P.O. Box 410 Schofield, WI 54476-0410

Subj: RENEWAL OF TYPE APPROVAL OF FIRE DAMPERS

Dear Mr. Talwar:

In response to your e-mail of August 11, 2014, we are granting your request for renewal of U.S. Coast Guard type approval of your series IMO-310, SSIMO-310, IMO-311, and SSIMO-311 fire dampers. A replacement Certificate of Approval is enclosed. To prevent a lapse in approval, the certificate was dated 9 August 2014, the expiration date of your previous certificate.

The enclosed certificate will remain valid for five years from the date of issuance, unless we suspend, withdraw, or terminate it. Approval is contingent upon the continued UL Listing of the dampers. Other terms of approval are on the reverse of the certificate.

Please note that under the 2010 FTP Code, we can renew approvals only if the test reports on which they are based are not more than 15 years old. The current approval is supported by a test report from 2004. Therefore when this approval expires in 2019, we will be able to renew it only if the products are retested.

If you have any questions or concerns, please contact Laurence E. Fisher at (202)-372-1447 or Laurence.E.Fisher@uscg.mil.

K. J. HEINZ

Chief Lifesaving and Fire Safety Division

U. S. Coast Guard

By direction

Encl.