


Item #

October 2007





### **QUICK APPLICATION**

The hood(s) shall contain a factory engineered and prepiped, UL Listed, Dual Agent, ANSUL® Piranha™ restaurant fire suppression system. When activated, the system discharges a fixed amount of wet chemical agent followed by water through the same nozzles. The regulated release assembly shall contain an anti-siphon valve to prevent back-siphonage of possible contaminated water into the potable water supply. A lockable water valve is required for this system (provided and installed by others). This system hooks up to the potable water supply or building sprinkler system, and requires a water pressure of 22 to 100 psi. The system piping shall be installed in the hood at the time of construction above the hood or within the supply plenum, and shall be concealed from view. No exposed piping is acceptable, with the exception of appliance drops. The system shall be capable of automatic detection and actuation and/or remote manual actuation. The system shall have the fire suppression capabilities to protect the duct(s), plenum(s), filter area(s) and cooking equipment.

The **Prepipe only** system includes schedule 40 black iron pipe, detectors, and chrome appliance drops. The remainder of the system is *not included* and is provided by others. Available for any jobsite.

The **US** system includes all parts to complete the system as well as field installation and certification. Mechanical or electrical gas valves shall be available for gas line shutoff applications and two (DPDT) double pull double throw microswitches for activation of the shunt trip breaker (provided by others) for electrical equipment. The system shall also include the release assembly, agent cylinder, agent, detectors, fusible links, liquidtight fittings, remote manual pull station, and schedule 40 black iron pipe with chrome sleeving for exposed areas. A certified local Ansul® distributor shall be selected by the factory for final system hook-up.

The Export system includes schedule 40 black iron pipe, detectors, chrome appliance drops, additional conduit and black iron to complete the system, the release assembly, agent cylinder, agent, detectors, fusible links, liquidtight fittings, remote manual pull station and gas valve. The field installed parts will be shipped to the freight forwarder by the manufacturer in a seperate shipment. The remainder of the system is *not included* and is provided by others.

Due to continuous research Greenheck reserves the right to change specifications without notice.

Ansı	ıl®	Piranh	าa™	Dual	Agent
Fire	Sup	press	ion S	Syste	m

# Type:

□ Dual Agent - Ansul® Piranha™

# Style:

- ☐ Prepipe (Any US or Export job)
- ☐ US (Continental United States only)
- □ Export (Any jobsite outside the Continental United States)

#### **STANDARD FEATURES:**

- UL and ULC Listed Meets UL 300 requirements
- Liquid tight fittings for all hood penetrations where fully welded
- · Dual Agent water and chemical
- Overlapping appliance protection
- · Chrome appliance drops

#### **OPTIONS:**

- Mechanical Gas Shut-Off Valves
  - \_\_ 3/4 in. (19 mm) \_\_ 1 in. (25 mm) \_\_ 1 1/4 in. (32 mm)
  - \_\_ 1 1/2 in. (38 mm) \_\_ 2 in. (50 mm) \_\_ 2 1/2 in. (64 mm)
  - \_\_ 3 in. (76 mm)
- ☐ Electrical Gas Shut-Off Valves
  - \_\_\_ 3/4 in. (19 mm) \_\_ 1 in. (25 mm) \_\_ 1 1/4 in. (32 mm)
  - \_\_ 1 1/2 in. (38 mm) \_\_ 2 in. (50 mm) \_\_ 2 1/2 in. (64 mm)
  - \_\_ 3 in. (76 mm)
- No Gas Valve (for electrical cooking appliance line-ups only)



The **Dual Agent Fire Suppression System** is ideally suitable for use in restaurants, hospitals, nursing homes, hotels, schools, airports and other similar facilities.

The system discharges wet chemical onto the hazard area first, with water following. This makes the Piranha™ system fifteen times faster at reducing grease temperature below the reflash point, preventing any possibility of the fire starting again.

#### **Code Information**

The Ansul® - PIRANHA<sup>™</sup> Restaurant Fire Suppression System is constructed in compliance with the following:

- National Fire Protection Association (NFPA) Bulletin #96 and #17A
- UL Standard 300 Listed •UL Standard 2092 Listed
- International Association of Plumbing and Mechanical Officials (IAPMO) Interim Guide IGC 113-97



# ANSUL® PIRANHA™ DUAL AGENT FIRE SUPPRESSION PROGRAM

## This program applies only to the continental United States

The basic wet chemical fire suppression system includes the following:

- Pre-piping of the kitchen hood with schedule 40 black iron pipe and chrome appliance drops
- Fuel shut-off device:
  - A. \*Choice of a mechanical gas valve or
  - B. \*Choice of an electrical gas valve with a manual reset relay.
  - (The installation of the valve is the responsibility of the plumbing contractor)
- One double-pole, double throw microswitch is provided for use with electric appliances. This device can also be used with alarm systems, fan shut down, and electric gas solenoid valves. (The wiring of this device is the responsibility of the electrical contractor.)
- All detectors, links\*, release mechanism, tank and fire suppression agent\*.
- One manual pull station for remote mounting. (this must be in the path of egress, at a maximum distance of 20 ft. (6.1 meters) from the release mechanism)
- An Ansul® tank and release mechanism housed in a cabinet (for remote mounting only).
- Final field hook-up\* to be performed by a non-union certified Ansul® distributor.
- Greenheck Hood Mounted Fire Cabinet Hook-Up to consist of:
   Hook-up of detection lines, hook-up of supply lines, mount and hook-up of remote manual pull, hook-up of mechanical
   gas valve (if applicable), charge and tag system.
- Greenheck Remote Mounted Fire Cabinet Hook-Up to consist of:
   Hang automan and additional tanks if multiple system, hook-up of detection lines, hook-up of supply lines, mount and hook-up of remote manual pull, hook-up of mechanical gas valve (if applicable), charge and tag system.

  Factory coordination of final system hook-up between jobsite contact and the assigned Ansul® distributor.
- Two trips out to the jobsite is included (system installation and test)
- Any state or local installation permits
- Puff or Air test
- \* Items supplied by the assigned Ansul® distributor

#### The basic wet chemical fire suppression system does not include the following:

- · Special drawings required by state or local codes
- Full dump test, system testing other that what is specified on the restaurant system installation manual, or special requirements to satisfy a state or local code
- Union labor, government labor, or prevailing wages required for final field hook-up
- Special classes or additional labor for access to security sensitive areas
- A lockable water valve (required for this system and provided and installed by others) This system hooks up to the potable water supply or building sprinkler system, and requires a water pressure of 30 to 100 psi.
- Installation of the gas shut-off valve (gas piping connections)
- Rough-in of hidden conduit for remote pull stations (flush mount) or gas valves
- Installation of more that one (1) remote pull station per system
- Pull stations installed at a distance greater that 20 feet (6.1 meters)
- Release mechanisms and tanks installed at a distance greater than 60 inches (1.5 meters)
- The cost of and installation of any electrical shut-off hardware other than the snap action switch, manual reset relay or pressure switch (i.e. shunt trip breaker or electrical contactors)
- All electrical connections required for fan shutdown, shut down of electric cooking equipment, connections from the restaurant system to any fire alarm control panel or system
- More than two trip to the jobsite or special transportation, or overnight lodging required for hook-ups in remote locations (normal travel distance is defined as the first 50 miles (80.5 km) from the distributor's office)
- · Any dismantling or reassembly required to gain access to the fire suppression piping located on top of the hood.
- Parts or labor required to correct piping due to cooking equipment changes or deviations from plans
- · Any charges for missing or additional parts other than those indicated on the attached fire suppression detail

Note: The customer is responsible for and will be invoiced separately for any additional parts or services not covered in the above items.