

## Relay Box

\*\*\*\*\*

Note to User: This document is subject to copyright protection and is proprietary to Greenheck Fan Corporation. However, Greenheck Fan Corporation authorizes the user a limited non-exclusive license to use this document or portions of it for the purpose of preparing written product specifications. All information in this document as provided by Greenheck Fan Corporation is informational in nature and is provided without representation or warranty of any kind as to the user or any other party, including, without limitation, ANY IMPLIED WARRANTY OF MERCHANTABILITY, FITNESS FOR PARTICULAR PURPOSE, OR NON-INFRINGEMENT. To the greatest extent permitted by applicable law, Greenheck Fan Corporation assumes no liability, and User assumes all liability and risk, for the use or results from the use of this document or the information contained herein, whether as modified by the user or not. Users should consult [www.greenheck.com](http://www.greenheck.com) to verify that this document represents the most current version.

\*\*\*\*\*

Provide Greenheck Relay Control Box as shown on plans and in accordance with the following specification:

The Relay Box shall be constructed of 16 gauge 300 series stainless steel and be NEMA 1 type enclosure. The pre-engineered relay box shall be pre-wired from the factory, include a wiring diagram in the control box and provide an interface to shut off the supply fan in a fire condition. The relay box requires all motors to have thermal overloads and be capable of operating a maximum of 6 fans utilizing single phase power only (120, 208 or 230 volt). Each fan shall have its own power source provided by others.

All electrical components shall be UL listed or Classified where applicable and wired in compliance with the National Electrical Code.

Due to continuous research Greenheck reserves the right to change specifications without notice.

## Switches Only

Provide Switches as shown on plans and in accordance with the following specification:

Switches only shall be provided on a switch plate mounted to the face of the hood, shipped loose for installation by others, attached to utility cabinet or utility distribution system. The switches shall be to control the lights, fans or call for heating or cooling (tempering) from the MUA unit. All wiring will be by others for the switches only selection.

Due to continuous research Greenheck reserves the right to change specifications without notice.